

CERTIFICATE OF CONFORMITY

Certificate number

No: 2618/0359/IND-CER

Holder

NingBo Deye Inverter Technology Co., Ltd. No. 26 South YongJiang Road, NingBo, China

Trademark

Deve Tech, Group Deye 後業

Tested model

SUN-6K-G

Variant models

SUN-5K-G / SUN-3.6K-G / SUN-3K-G / SUN-2K-G / SUN-1K-G

Type of generating unit

Utility Interactive Inverter

Technical Data

Nominal Power [kW]

3.6

Nominal Voltage [V]

50

Nominal Frequency [Hz]

Display software version: Ver 144

230

Control software version: Ver 3109

Firmware version Number of phases

Isolation transformer

Single phase

NO

This certificate of conformity confirms that one sample of the above-mentioned product is in compliance with:

- IEC 60068-2-1:2007. Environmental testing. Part 2-1: Tests. Test Ae: Cold.
- IEC 60068-2-2:2007. Environmental testing. Part 2-2: Tests. Test Be: Dry heat. IEC 60068-2-14:2009. Environmental testing. Part 2-14: Tests. Test Nb: Change of temperature.
- IEC 60068-2-30:2005. Environmental testing. Part 2-30: Tests. Test Db-Variant 1: Damp heat, cyclic (12 h + 12 h cycle).
- IEC 61683:1999. Photovoltaics systems Power conditioners Procedure for measuring efficiency.
- IEC 62116:2014. Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
- IEC 61727:2004. Photovoltaics (PV) systems Characteristics of the utility interface

This certificate of conformity is based upon the test results of the test reports number below detailed and is only valid when the product is manufactured in accordance with the tested sample.

- 2218 / 0359 A for IEC 61727:2004
- 2218 / 0359 B for IEC 62116:2014
- 2218 / 0359 C for IEC 61683:1999
- 2218 / 0359 D for IEC 60068-2-1:2007; IEC 60068-2-2:2007; IEC 60068-2-14:2009; IEC 60068-2-30:2005

This certificate will expire in 5 years from the release date of these tests reports, issued the 22th June of 2018.

Madrid, 22th of June 2018

Daniel Arranz Muñiz Certification Manager

